

**NOTICE TO ALL CONTRACTORS AND SUB-CONTRACTORS**  
August 31, 2022

**Project Name: USD 305-Jerry Ivey Memorial Park – New Tennis Courts – Proj 21-3201**

**ADDENDUM NO. 2**

**YOU ARE INSTRUCTED TO READ AND TO NOTE THE FOLLOWING DESCRIBED CHANGES, CORRECTIONS, CLARIFICATIONS, OMISSIONS, DELETIONS, ADDITIONS, APPROVALS, AND STATEMENTS PERTINENT TO THE CONTRACT AND CONSTRUCTION DOCUMENTS. THIS ADDENDUM IS A PART OF THE CONTRACT AND CONSTRUCTION DOCUMENTS AND SHALL GOVERN IN THE PERFORMANCE OF THE WORK.**

***Bid Date: Wednesday, September 7, 2022 at 10:00 a.m.***

**GENERAL**

1. The Pre-Bid Sign-In Sheet is attached, showing the General Contractors bidding.
2. For reference, previous soils reports for South High have been added to the JGR Plan Room. These provide soil bearing information for areas close to the project site. These reports are for:
  - a. 2014 South High School Additions. Note boring logs 7, 8, and 9 are located directly west of the new tennis courts project area.
  - b. 2020 South High Softball Fields. This was completed for installation of new turf.

Jeff Gillam  
Charles Renz  
Mark Regier  
Maggie Gillam  
Chris Gillam

**ARCHITECTURAL – Drawings**

1. Sheet D1.1 - Note 2. Correction, the existing tennis courts to be removed are concrete, not asphalt.
2. Sheet A1.1 - Clarification, at the location of the new tennis courts, it is intended for bidding purposes, the court areas to be excavated minimum 24" below the bottom of the court slab, compacted, moisture conditioned, and filled with LVC in maximum 8" lifts. The over excavation shall extend a minimum of 5'-10' outside each court area.
3. Sheet A1.1 - Clarification, for bidding purposes, the contractor shall assume that the existing on-site soil materials is not suitable for re-use as LVC and to be brought from off-site.
4. Sheet A2.1 - Clarification. There is to be one (1) concrete hitting wall per Alternate 1. The hitting wall is to be located south of Court 1. There is no hitting wall at the east bank of courts.

**Receipt of this Addendum shall be noted on the Bid Form.**

END OF ADDENDUM NO. 2



730 N. Ninth (67401)  
P.O. Box 2928  
Salina, KS 67402-2928  
(785) 827-0386

Attachments  
Pre-Bid Sign-In Sheet

1881 Main St., Suite 301  
Kansas City, MO 64108

