

Architecture  
Interior Design  
Graphic Design  
Facility Planning

**NOTICE TO ALL CONTRACTORS AND SUB-CONTRACTORS – June 27, 2022**

**The Reserves at South Lake, Grinnell, Iowa – Proj 21 -3118**

**ADDENDUM NO. 3**

YOU ARE INSTRUCTED TO READ AND TO NOTE THE FOLLOWING DESCRIBED CHANGES, CORRECTIONS, CLARIFICATIONS, OMISSIONS, DELETIONS, ADDITIONS, APPROVALS AND STATEMENTS PERTINENT TO THE CONTRACT AND CONSTRUCTION DOCUMENTS. THIS ADDENDUM IS A PART OF THE CONTRACT AND CONSTRUCTION DOCUMENTS AND SHALL GOVERN IN THE PERFORMANCE OF THE WORK.

**MECHANICAL/ELECTRICAL/PLUMBING – Drawings**

1. The electric company, Alliant Energy, requires termination cabinets between their transformers and their meter centers. The Site Plan, Building Plans, and Riser Diagrams have been revised to reflect the addition of the new equipment and conduits required.
  - a) Base Bid: Gas System – Sheets E1.0, E6.2, ME1.1, ME1.2
  - b) Alternate Bid #4: All-Electric System – Sheets E1.0, E6.2, ME1.1 and ME1.2

Jeff Gillam  
Charles Renz  
Mark Regier  
Maggie Gillam  
Chris Gillam

***Receipt of this Addendum shall be noted on the Bid Form.***

**END OF ADDENDUM No. 3**



730 N. Ninth (67401)  
P.O. Box 2928  
Salina, KS 67402-2928  
(785) 827-0386  
Fax (785) 827-0392

